

Orono Veazie Water District Halogenated Acetic Acids Historical Results

<u>Date Collected</u>	<u>Analyte</u>	<u>Conc</u>	<u>UoM</u>	<u>Facility Name</u>	<u>Test</u>
<u>2022</u>					
6/6/2022	HAA5		ug/L	1215 State ST Veazie	COMPLIANCE
6/6/2022	HAA5	18	ug/L	UM STUDENT UNION	COMPLIANCE
2/9/2022	HAA5	19	ug/L	1215 State ST Veazie	COMPLIANCE
2/9/2022	HAA5	16	ug/L	UM STUDENT UNION	COMPLIANCE
<u>2021</u>					
11/16/2021	HAA5	9.6	ug/L	1215 State ST Veazie	COMPLIANCE
11/16/2021	HAA5	26	ug/L	UM STUDENT UNION	COMPLIANCE
8/10/2021	HAA5	11	ug/L	1215 State ST Veazie	COMPLIANCE
8/10/2021	HAA5	21	ug/L	UM STUDENT UNION	COMPLIANCE
5/24/2021	HAA5	28	ug/L	1215 State ST Veazie	COMPLIANCE
5/24/2021	HAA5	23	ug/L	UM STUDENT UNION	COMPLIANCE
2/10/2021	HAA5	18	ug/L	1215 State ST Veazie	COMPLIANCE
2/10/2021	HAA5	19	ug/L	UM STUDENT UNION	COMPLIANCE
<u>2020</u>					
11/10/2020	HAA5	5.2	ug/L	1215 State ST Veazie	COMPLIANCE
11/10/2020	HAA5	25	ug/L	UM STUDENT UNION	COMPLIANCE
	HAA5		ug/L	1215 State ST Veazie	COMPLIANCE
	HAA5		ug/L	UM STUDENT UNION	COMPLIANCE
5/11/2020	HAA5	13	ug/L	1215 State ST Veazie	COMPLIANCE
5/11/2020	HAA5	12	ug/L	UM STUDENT UNION	COMPLIANCE
2/10/2020	HAA5	8.9	ug/L	1215 State ST Veazie	COMPLIANCE
2/10/2020	HAA5	12	ug/L	UM STUDENT UNION	COMPLIANCE
<u>2019</u>					
11/12/2019	HAA5	3.7	ug/L	1215 State ST Veazie	COMPLIANCE
11/12/2019	HAA5	17	ug/L	UM STUDENT UNION	COMPLIANCE
8/12/2019	HAA5	22	ug/L	1215 State ST Veazie	COMPLIANCE
8/12/2019	HAA5	34	ug/L	UM STUDENT UNION	COMPLIANCE
5/13/2019	HAA5	9.6	ug/L	1215 State ST Veazie	COMPLIANCE
5/13/2019	HAA5	14	ug/L	UM STUDENT UNION	COMPLIANCE
2/11/2019	HAA5	9.4	ug/L	1215 State ST Veazie	COMPLIANCE
2/11/2019	HAA5	12	ug/L	UM STUDENT UNION	COMPLIANCE
<u>2018</u>					
11/9/2018	HAA5	3.6	ug/L	1215 State ST Veazie	COMPLIANCE
11/9/2018	HAA5	17	ug/L	UM STUDENT UNION	COMPLIANCE
8/15/2018	HAA5	2.2	ug/L	1215 State ST Veazie	COMPLIANCE
8/15/2018	HAA5	10	ug/L	UM STUDENT UNION	COMPLIANCE
5/10/2018	HAA5	5.4	ug/L	1215 State ST Veazie	COMPLIANCE
5/10/2018	HAA5	11	ug/L	UM STUDENT UNION	COMPLIANCE
2/8/2018	HAA5	5.4	ug/L	1215 State ST Veazie	COMPLIANCE
2/8/2018	HAA5	9.2	ug/L	UM STUDENT UNION	COMPLIANCE
<u>2017</u>					
11/8/2017	HAA5	3.2	ug/L	1215 State ST Veazie	COMPLIANCE

11/8/2017	HAA5	21	ug/L	UM STUDENT UNION	COMPLIANCE
8/10/2017	HAA5	0	ug/L	1215 State ST Veazie	COMPLIANCE
8/10/2017	HAA5	14	ug/L	UM STUDENT UNION	COMPLIANCE
5/10/2017	HAA5	6.6	ug/L	1215 State ST Veazie	COMPLIANCE
5/10/2017	HAA5	9.7	ug/L	UM STUDENT UNION	COMPLIANCE
2/9/2017	HAA5	4	ug/L	1215 State ST Veazie	COMPLIANCE
2/9/2017	HAA5	8.7	ug/L	UM STUDENT UNION	COMPLIANCE
<u>2016</u>					
11/10/2016	HAA5	1.7	ug/L	1215 State ST Veazie	COMPLIANCE
11/10/2016	HAA5	14	ug/L	UM STUDENT UNION	COMPLIANCE
8/11/2016	HAA5	2.8	ug/L	1215 State ST Veazie	COMPLIANCE
8/11/2016	HAA5	6	ug/L	UM STUDENT UNION	COMPLIANCE
5/11/2016	HAA5	4.3	ug/L	1215 State ST Veazie	COMPLIANCE
5/11/2016	HAA5	11	ug/L	UM STUDENT UNION	COMPLIANCE
2/10/2016	HAA5	31	ug/L	UM STUDENT UNION	COMPLIANCE
2/10/2016	HAA5	9.9	ug/L	1215 State ST Veazie	COMPLIANCE
<u>2015</u>					
11/10/2015	HAA5	22	ug/L	UM STUDENT UNION	COMPLIANCE
11/10/2015	HAA5	3.9	ug/L	1215 State ST Veazie	COMPLIANCE
8/12/2015	HAA5	38	ug/L	UM STUDENT UNION	COMPLIANCE
8/12/2015	HAA5	7.3	ug/L	1215 State ST Veazie	COMPLIANCE
5/13/2015	HAA5	21	ug/L	UM STUDENT UNION	COMPLIANCE
5/13/2015	HAA5	13	ug/L	1215 State ST Veazie	COMPLIANCE
2/12/2015	HAA5	28	ug/L	UM STUDENT UNION	COMPLIANCE
2/12/2015	HAA5	18	ug/L	1215 State ST Veazie	COMPLIANCE
<u>2014</u>					
11/17/2014	HAA5	<5	ug/L	1215 State ST Veazie	COMPLIANCE
11/17/2014	HAA5	48	ug/L	UM STUDENT UNION	COMPLIANCE
8/20/2014	HAA5	68	ug/L	1215 State ST Veazie	COMPLIANCE
8/20/2014	HAA5	<5	ug/L	UM STUDENT UNION	COMPLIANCE
6/11/2014	HAA5	61	ug/L	UM STUDENT UNION	COMPLIANCE
6/11/2014	HAA5	13	ug/L	1215 State ST Veazie	COMPLIANCE
2/26/2014	HAA5	37	ug/L	1212 State St Veazie	COMPLIANCE
2/12/2014	HAA5	34	ug/L	UM STUDENT UNION	COMPLIANCE
2/13/2014	HAA5	38	ug/L	Existing Stage 1 Site	COMPLIANCE
<u>2013</u>					
11/19/2013	HAA5	53	ug/L	UM STUDENT UNION	COMPLIANCE
11/19/2013	HAA5	42	ug/L	Existing Stage 1 Site	COMPLIANCE
9/20/2013	HAA5	7.7	ug/L	DISTRIBUTION SYSTEM	COMPLIANCE
5/16/2013	HAA5	47	ug/L	DISTRIBUTION SYSTEM	COMPLIANCE
3/21/2013	HAA5	45	ug/L	DISTRIBUTION SYSTEM	COMPLIANCE